

PL 00-611 WARSZAWA

ul. Filtrowa 1

tel.: (+48 22) 825-04-71 (+48 22) 825-76-55 fax: (+48 22) 825-52-86

www.itb.pl





European Technical Assessment

ETA-17/0237 of 15/05/2017

General Part

Technical Assessment Body issuing the European Technical Assessment

Trade name of the construction product

Product family to which the construction product belongs

Manufacturer

Manufacturing plant

This European Technical Assessment contains

This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of

Instytut Techniki Budowlanej

G&B Fissaggi SITA Acciaio CE7 GBK

Torque controlled expansion anchor of sizes M8, M10, M12, M16 and M20 for use in noncracked concrete

G&B Fissaggi S.r.l. Corso Savona, 22 10029 Villastellone (TO) Italy

Plant 1

12 pages including 3 Annexes which form an integral part of this Assessment

European Assessment Document (EAD) "Mechanical fasteners for use in concrete" EAD 330232-00-0601

This European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

Specific Part

1 Technical description of the product

The G&B Fissaggi SITA Acciaio CE7 GBK anchor in the sizes M8, M10, M12, M16 and M20 is made of galvanized steel. The anchor is placed into a drill hole and anchored by torque-controlled expansion.

An illustration and the description of the product are given in Annex A.

2 Specification of the intended use in accordance with the applicable European Assessment Document (EAD)

The performances given in Annex C are only valid if the anchor is used in compliance with the specifications and conditions given in Annex B.

The provisions made in this European Technical Assessment are based on an assumed working life of the anchor of 50 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer or Technical Assessment Body, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

3 Performance of the product and references to the methods used for its assessment

3.1 Performance of the product

3.1.1 Mechanical resistance and stability (BWR 1)

| Essential characteristic | Performance |
|--|-------------|
| Characteristic resistance to tension load (static and quasi-static loading), displacements | Annex C1 |
| Characteristic resistance to shear load (static and quasi-static loading), displacements | Annex C2 |

3.1.2 Safety in case of fire (BWR 2)

| Essential characteristic | Performance | | |
|--------------------------|---|--|--|
| Reaction to fire | Anchors satisfy requirements for Class A1 | | |
| Resistance to fire | No performance assessed | | |

3.2 Methods used for the assessment

The assessment of fitness of anchors for the declared intended use in relation to the requirements for mechanical resistance and stability and safety in case of fire has been made in accordance with the EAD 330232-00-0601 "Mechanical fasteners for use in concrete".

4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

According to Decision 96/582/EC of the European Commission the system 1 of assessment and verification of constancy of performance applies (see Annex V to Regulation (EU) No 305/2011).

5 Technical details necessary for the implementation of the AVCP system, as provided in the applicable European Assessment Document (EAD)


Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited in Instytut Techniki Budowlanej.

For type testing the results of the tests performed as part of the assessment for the European Technical Assessment shall be used unless there are changes in the production line or plant. In such cases the necessary type testing has to be agreed between Instytut Techniki Budowlanej and the notified body.

Issued in Warsaw on 15/05/2017 by Instytut Techniki Budowlanej

Marcin M. Kruk, PhD

Director of ITB



Marking:

- expansion sleeve: GBK (marking identifying the product)
- bolt: dXL/t (d diameter, L length, t thickness of fixed element)
- one letter marking on the tip of the bolt, according to table below:

| Marking letter | Length L [mm] |
|----------------|---------------|
| Α | 60 - 67 |
| В | 68 – 80 |
| С | 81 – 87 |
| D | 88 – 92 |
| E | 93 – 97 |
| F | 98 – 105 |
| G | 106 – 112 |
| Н | 113 – 117 |
| 1 | 118 – 122 |
| J | 123 – 127 |
| К | 128 – 135 |
| L | 136 – 142 |
| M | 143 – 147 |
| N | 148 – 155 |
| 0 | 156 – 165 |
| Р | 166 – 175 |
| Q | 176 – 190 |
| R | 191 – 210 |
| S | 211 – 230 |
| Т | 231 – 255 |
| U | 256 – 275 |
| V | 276 – 290 |
| W | 291 – 315 |
| Х | 316 – 345 |
| Y | 346 – 375 |
| Z | 376 – 400 |

| G&B Fissaggi SITA Acciaio CE7 GBK | Annex A1 |
|-----------------------------------|--|
| Product description Anchor | of European Technical Assessment ETA-17/0237 |

Table A1: G&B Fissaggi SITA Acciaio CE7 GBK anchor dimensions

| Type of anchor | | | d d _k | | L | L _{clip} | SW ²⁾ |
|----------------|---------|-----------------------------|------------------|------|-----------|-------------------|------------------|
| Size | Marking | t _{fix} 1) [mm] | [mm] [mm] | | [mm] | [mm] | [mm] |
| M8 | GBK M8 | 2 – 92 | 8 | 7,8 | 60 – 150 | 15 | 13 |
| M10 | GBK M10 | 5 – 135 | 10 | 9,8 | 70 – 200 | 18 | 17 |
| M12 | GBK M12 | 3 – 278 | 12 | 11,8 | 85 – 360 | 20 | 19 |
| M16 | GBK M16 | 5 – 285 | 16 | 15,8 | 120 – 400 | 24 | 24 |
| M20 | GBK M20 | 5 – 135 | 20 | 19,8 | 140 – 270 | 28 | 30 |

¹⁾ thickness of the fixed element

| G&B Fissaggi SITA Acciaio CE7 GBK | Annex A2 |
|-----------------------------------|--|
| Product description Dimensions | of European Technical Assessment ETA-17/0237 |

²⁾ torque wrench width




Table A2: Materials

| art | Designation | Material | Coating | | |
|-----|----------------|---|-----------------------------------|--|--|
| 1 | Bolt | Cold-formed steel, $f_{uk} \geq \begin{cases} 500 \text{ MPa for M8 - M16} \\ 480 \text{ MPa for M20} \\ f_{yk} \geq 400 \text{ MPa} \end{cases}$ | | | |
| 2 | Expansion clip | Cold-formed steel | Zinc plated ≥ 5 µm EN ISO 4042 | | |
| 3 | Washer | ISO 7089 (DIN 125-A) or ISO 7093 (DIN 9021) | EN 130 4042 | | |
| 4 | Hexagon nut | EN ISO 898-2 carbon steel class 8 / DIN 934 carbon | | | |

| G&B Fissaggi SITA Acciaio CE7 GBK | Annex A3 |
|-----------------------------------|----------------------------------|
| Product description | of European Technical Assessment |
| Materials | ETA-17/0237 |

Specification of intended use

Anchorages subject to:

Static and quasi-static loads.

Base material:

- Reinforced or unreinforced normal weight concrete of strength classes C20/25 at minimum and C50/60 at maximum according to EN 206.
- Non-cracked concrete.

Use conditions (environmental conditions):

Structures subject to dry internal conditions.

Design:

- The anchorages under static and quasi-static loads are designed in accordance with EOTA Technical Report TR 055, under the responsibility of an engineer experienced in anchorages and concrete work.
- The position of the anchor is indicated on the design drawings.
- Verifiable calculation notes and drawings are taking account of the loads to be transmitted.

Installation of anchors:

- Anchor installation carried out by appropriately qualified personnel and under the supervision of the person responsible for technical matters of the site.
- Use of the anchor only as supplied by the manufacturer without exchanging any component of the anchor.
- Anchor installation in accordance with the manufacturer's specification and drawings and using the appropriate tools.
- Checks before placing the anchor to ensure that the strength class of the concrete in which the anchor is to be placed is in the range given and is not lower than that of the concrete to which the characteristic loads apply.
- Check of concrete being well compacted, e.g. without significant voids.
- Effective anchorage depth, edge distances and spacings not less than the specified values without minus tolerances.
- Positioning of the drill holes without damaging the reinforcement.
- Hole drilling by hammer drill.
- Cleaning of the hole of drilling dust.
- Application of the torque moment using a calibrated torque wrench.
- In case of aborted hole: new drilling at a minimum distance away of twice the depth of the aborted hole or smaller distance if the aborted drill hole is filled with high strength mortar and if under shear or oblique tension load it is not in the direction of load application.

| G&B Fissaggi SITA Acciaio CE7 GBK | Annex B1 |
|-----------------------------------|----------------------|
| | of European |
| Intended use | Technical Assessment |
| Specifications | ETA-17/0237 |




Table B1: Installation parameters

| Anchor size | | M8 | M10 | M12 | M16 | M20 |
|---|-------------------------|-----|-----|-----|-----|-----|
| Effective anchorage depth | h _{ef} [mm] | 45 | 50 | 60 | 85 | 100 |
| Nominal drill hole diameter | d _o [mm] | 8 | 10 | 12 | 16 | 20 |
| Depth of drill hole | h ₀ ≥ [mm] | 60 | 65 | 80 | 110 | 125 |
| Embedment depth | h _{nom} ≥ [mm] | 50 | 55 | 70 | 100 | 115 |
| Diameter of clearance hole in the fixture | d _f ≤ [mm] | 9 | 12 | 14 | 18 | 22 |
| Installation torque | T _{inst} [Nm] | 20 | 35 | 55 | 100 | 150 |
| Minimum thickness of member | h _{min} [mm] | 100 | 100 | 120 | 170 | 200 |
| Minimum spacing | s _{min} [mm] | 61 | 68 | 81 | 115 | 135 |
| Minimum edge distance | c _{min} [mm] | 61 | 68 | 81 | 115 | 135 |

| G&B Fissaggi SITA Acciaio CE7 GBK | |
|--------------------------------------|--|
| | Annex B2 |
| Intended use Installation parameters | of European Technical Assessment ETA-17/0237 |




Table C1: Design method A, characteristic values for tension loads

| Anchor size | YM . | M8 | M10 | M12 | M16 | M20 |
|--|---|------|------|---------|------|-------|
| Steel failure | | | | | | |
| Characteristic resistance | N _{Rk,s} [kN] | 18,3 | 29,0 | 42,2 | 78,5 | 117,6 |
| Modulus of elasticity | E _s [N/mm ²] | | | 210 000 | | |
| Partial safety factor | γ _{Ms} ¹⁾ | | | 1,50 | | |
| Pull-out failure | | | | | | |
| Characteristic resistance in non-cracked concrete C20/25 | N _{Rk,p} [kN] | 9 | 12 | 16 | 16 | 30 |
| Installation safety factor | $\gamma_2^{(2)} = \gamma_{\text{inst}}^{(3)(4)}$ | 1,2 | 1,2 | 1,2 | 1,2 | 1,0 |
| Increasing factor for concrete C30/37 | | 1,22 | 1,22 | 1,22 | 1,22 | 1,22 |
| Increasing factor for concrete C40/50 | Ψc | 1,41 | 1,41 | 1,41 | 1,41 | 1,41 |
| Increasing factor for concrete C50/60 | | 1,55 | 1,55 | 1,55 | 1,55 | 1,55 |
| Concrete cone failure and splitting | failure | | | | | |
| Effective anchorage depth | h _{ef} [mm] | 45 | 50 | 60 | 85 | 100 |
| Factor for non-cracked concrete | $k_1^{(2)} = k_{ucr}^{(3)}$ | 10,1 | 10,1 | 10,1 | 10,1 | 10,1 |
| Factor for non-cracked concrete | $k_1^{4)} = k_{ucr,N}^{4)}$ | 11,0 | 11,0 | 11,0 | 11,0 | 11,0 |
| Spacing | s _{cr,N} [mm] | 135 | 150 | 180 | 255 | 300 |
| Edge distance | c _{cr,N} [mm] | 68 | 75 | 90 | 128 | 150 |
| Characteristic resistance for splitting | $N_{Rk,c}^{0} = N_{Rk,sp}^{0} = N_{Rk,sp}^{0} = N_{Rk,sp}^{0} $ | 9 | 12 | 16 | 16 | 30 |
| Characteristic spacing | s _{cr,sp} [mm] | 225 | 250 | 300 | 425 | 500 |
| Characteristic edge distance | c _{cr,sp} [mm] | 113 | 125 | 150 | 213 | 250 |
| Installation safety factor | $\gamma_2^{(2)} = \gamma_{\text{inst}}^{(3)(4)}$ | 1,2 | 1,2 | 1,2 | 1,2 | 1,0 |

Table C2: Displacements under tension loads

| Anchor size | | M8 | M10 | M12 | M16 | M20 |
|--------------|----------------------------|-----|-----|-----|-----|------|
| Tension load | N [kN] | 3,8 | 5,0 | 8,7 | 9,8 | 14,4 |
| Displacement | δ _{NO} [mm] | 0,8 | 1,9 | 3,7 | 3,7 | 3,7 |
| | $\delta_{N_{\infty}}$ [mm] | 1,2 | 1,2 | 1,2 | 1,2 | 1,2 |

G&B Fissaggi SITA Acciaio CE7 GBK Annex C1 of European **Technical Assessment Performances** ETA-17/0237 Design method A, characteristic values for tension loads, displacements

¹⁾ in absence of other national regulations 2) parameter for design according to ETAG 001 Annex C 3) parameter for design according to CEN/TS 1992-4-4:2009 4) parameter for design according to FprEN 1992-4:2016

Table C3: Design method A, characteristic values for shear loads

| Anchor size | | M8 | M10 | M12 | M16 | M20 |
|--|---|------|------|------|-------|-------|
| Steel failure without lever arm | | | | | | |
| Characteristic resistance | $V_{Rk,s}^{(2)3)} = V_{Rk,s}^{(4)}[kN]$ | 9,2 | 14,5 | 21,1 | 39,3 | 58,8 |
| Ductility factor | $k^{2)} = k_2^{3)} = k_7^{4)}$ | 0,8 | 0,8 | 0,8 | 0,8 | 0,8 |
| Partial safety factor | γ _{Ms} ¹⁾ | 1,25 | | | | |
| Steel failure with lever arm | | | | | | |
| Characteristic bending resistance | M ⁰ _{Rk,s} [Nm] | 18,8 | 37,4 | 65,6 | 166,6 | 311,8 |
| Partial safety factor | γ _{Ms} ¹⁾ | 1,25 | | | | |
| Concrete pry-out failure | | | | | | |
| Concrete pry-out failure factor | $k^{2)}=k_3^{(3)}=k_8^{(4)}$ | 1,0 | 1,0 | 2,0 | 2,0 | 2,0 |
| Partial safety factor | γ _{Mc} ¹⁾ | 1,5 | | | | |
| Concrete edge failure | | | | | | |
| Effective length of anchor under shear loading | l _f [mm] | 45 | 50 | 60 | 85 | 100 |
| Outside diameter of anchor | d _{nom} [mm] | 8 | 10 | 12 | 16 | 20 |
| Partial safety factor | γ _{Mc} ¹⁾ | 1,5 | | | | |

Table C4: Displacements under shear loads

| Anche | or size | M8 | M10 | M12 | M16 | M20 |
|--------------|----------------------------|-----|-----|-----|------|------|
| Shear load | V [kN] | 2,7 | 6,2 | 8,3 | 13,7 | 25,1 |
| Displacement | δ _{VO} [mm] | 0,5 | 0,9 | 0,9 | 0,9 | 1,9 |
| | $\delta_{V_{\infty}}$ [mm] | 0,7 | 1,3 | 1,3 | 1,3 | 2,8 |

G&B Fissaggi SITA Acciaio CE7 GBK Annex C2 of European **Technical Assessment Performances** ETA-17/0237 Design method A, characteristic values for shear loads, displacements

¹⁾ in absence of other national regulations
2) parameter for design according to ETAG 001 Annex C
3) parameter for design according to CEN/TS 1992-4-4:2009
4) parameter for design according to FprEN 1992-4:2016